

EC Declaration of Conformity

INDEXA GmbH
Paul-Böhringer-Str. 3
74229 Oedheim
Deutschland

declares

that the product

Type designation: 8000 S

Specification: *Wireless Fire Detector*

Intended purpose: *Fire detection*

Frequency switching range: *1 RF channel 868,5 MHz*

RF power: *<25 mW ERP*

Channel separation: *> 25 kHz*

Duty cycle: *< 0,1 %*

Modulation: *FM*

Class of emission: *70K0F1DAN*

Equipment class /

complies with the essential requirements of § 3 and the other relevant provisions of the FTEG (Article 3 of the R&TTE Directive), when is used for its intended purpose.

Measures for the efficient use the radio frequency spectrum - Air interface of the radio systems pursuant to § 3(2) (Article 3(2))

Harmonised standards applied: *ETSI EN 300 220, ETSI EN 301 489-1, 3*

Protection requirements concerning electromagnetic compatibility § 3(1)(2), (Article 3(1)(b))

Harmonised standards applied: *EN 50130-4, EN 55022*

Health and safety requirements pursuant to § 3(1) 1. (Article 3(1) a))

Harmonised standard applied: *EN 60950*



Bell, Tim

(Gesell. Geschäftsfuehrer)

Oedheim

08.09.2006
